



NOTES:

1. ALL HDPE JOINTS SHALL BE BUTT FUSED. ALL PVC PIPE AND FITTINGS SHALL BE SCH. 80 PVC WITH THREADED JOINTS



Snyderville Basin Water
Reclamation District

DEAD END LOW-PRESSURE
FLUSHING CONNECTION

STANDARD DETAIL

LP-02

Revision Date: 2/23/26