



- NOTES:
1. 7' MINIMUM COVER FOR LOW-PRESSURE LATERALS LOCATED UNDER AREAS THAT MAY BE CLEARED OF SNOW AND HAVE VEHICULAR TRAFFIC.
 2. BENDS EXCEEDING 45° SHALL NOT BE USED.
 3. FUSION WELD OR SOLVENT WELD FITTINGS AND JOINTS REQUIRED ON VERTICAL BENDS AND ON SLOPES GREATER THAN 3:1 (33%).
 4. SEPARATION FROM AN ADJACENT RETAINING WALL FACE SHALL MEET THE MINIMUM VERTICAL DEPTH REQUIREMENTS.
 5. MINIMUM BURY DEPTH MUST BE ACHIEVED WITHIN 30" OF FOUNDATION WALL.